

Approval Number: 2010523
Test Report: M107047A-C



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

16th October 2020

Molecor Tecnologia S.L.
Ctra M-206 Torrejón-Loeches Km 3.1,
28890 Loeches,
Madrid,
Spain

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYVINYLCHLORIDE (PVC, PVC-U AND CPVC) - COMPONENTS.

5301

'TOM PVC-O Pipe'. Blue coloured PVC pipe which is manufactured by extrusion and molecular orientation. For use with water up to 60°C.

APPROVAL NUMBER: 2010523

APPROVAL HOLDER: MOLECOR TECNOLOGIA S.L.

The Scheme reserves the right to review approval.
Approval 2010523 is valid between October 2020 and October 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme